

Contact person RISE
Pär Johansson
Safety
+46 10 516 56 32
par.johansson@ri.se

Date
2019-06-14

Reference
7P02190Rev1

Page
1 (1)

AGC Glass Europe SA
4, Avenue Jean Monnet
BE-1347 LOUVAIN-LA-NUEVE
Belgien

Assessment of decorative film on glass

The glass panes named below can be equipped with decorative film on one or both sides without affecting the fire resistance performance negative.

The decorative film is designated 3M Scotchcal Clearview Graphic 8150 or Orafol Oracal 8300. The decorative film options are described in test report 2014-Efectis-R000838[Rev.1].

The glass panes which can be equipped with decorative film are Pyrobelite 9EG and Pyrobelite 10 for a fire resistance up to maximum 30 minutes and Pyrobel 16, Pyrobel 17N and Pyrobel 25 for a fire resistance up to maximum 60 minutes.

The fire resistance of each of the glass panes is not described in this assessment.

The assessment of the fire resistance of the construction is deemed to meet the level of compliance with the requirements in Boverket's (The Swedish National Board of Housing, Building and Planning) Building Regulations BBR 27 (BFS 2011:6 with changes up to and including BFS 2018:15) 5:112 and 5:231 and associated impact assessment.

The assessment is based on an analytic design through qualitative assessment according to Boverkets Allmänna råd 1993:2, utgåva 2, "Riktlinjer för typgodkännande brandskydd". (Boverket's General Recommendation 1993:2, edition 2. "Guidelines for fire technical approvals").

This assessment is based on test reports 2014-Efectis-R000838[Rev.1], dated December 2014 from Efectis Nederlands,12277A dated September 9, 2009 from Warringtonfiregent, 16015A-rev2 dated August 29, 2014, 331776 dated February 20, 2014, 14263A dated April 26, 2010 from Warringtonfiregent and 103010.45, dated May 4. 20'04 from SINTEF.

The assessment shall not be compared with a classification according to EN 13501-2.

This report is a revision and replaces the previous assessment 7P02190 dated April 7, 2017. This revision refers to: Renewal validity an minor updates of references.

This assessment is valid for two years.

RISE Research Institutes of Sweden AB **Safety - Fire Research Resistance**

Performed by

Examined by

Pär Johansson

Patrik Johansson

RISE Research Institutes of Sweden AB

Postal address	Office location	Phone / Fax / E-mail
Box 857	Brinellgatan 4	+46 10 516 50 00
SE-501 15 BORÅS	SE-504 62 BORÅS	+46 33 13 55 02
Sweden		info@ri.se

This document may not be reproduced other than in full, except with the prior written approval of RISE.